

INDEX

02.1	Fire safety
02.1a	Fire safety risk assessment form

02.1 Fire safety

- The setting supervisor has access to, or a copy of, the fire safety procedures specific to the building and ensure they align with these procedures. The setting supervisor makes reasonable adjustments as required to ensure the two documents do not contradict each other.

Fire safety risk assessment

02.1a Fire safety risk assessment form is carried out in each area of the setting by a competent person using the five steps to fire safety risk assessment as follows:

1. Identify fire hazards
 - Sources of ignition.
 - Sources of fuel.
 - Sources of oxygen (including oxygen tanks for disabled children).
2. Identify people at risk
 - People in and around the premises.
 - People especially at risk including very young babies, less ambulant disabled children or those using specialised equipment, such as splints, standing frames.
3. Evaluate, remove, reduce, and protect from the risk
 - Evaluate the risk of the fire occurring.
 - Evaluate the risk to people from a fire starting on the premises.
 - Remove and reduce the hazards that may cause a fire.
 - Remove and reduce the risks to people from a fire.
4. Record, plan, inform, instruct, train
 - Record significant findings and action taken.
 - Prepare an emergency plan.
 - Inform and instruct relevant people; inform and co-operate with others.

Wigmore Church and Community Under Fives Preschool – Fire Safety

- Provide training.

5. Review

- Keep assessment under review and revise when necessary.

The fire safety risk assessment focuses on the following for each area:

- Electrical plugs, wires, sockets.
- Electrical items.
- Gas boilers.
- Cookers.
- Matches.
- Flammable materials, including furniture, furnishings, paper etc.
- Flammable chemicals (which are also covered in COSHH).
- Means of escape.
- Any other, as identified.

Fire safety precautions include:

- A qualified electrician checks all electrical equipment annually.
- Any faulty electrical equipment is taken out of use and recorded as such or condemned (whichever is necessary).
- Sockets are covered. This is different to using plug socket inserts, a socket cover, covers the whole socket, including the switch and is safe to use.
- Water and electrical items do not come into contact; staff do not touch electrical items with wet hands.
- All fire safety equipment is checked annually.
- Gas boilers and cookers are checked and serviced annually by a Gas Safe registered engineer.
- If matches are used in the kitchen, they are kept in a drawer.
- Oxygen tanks.

Fire Drills

- Fire Drills (to include emergency evacuation procedures and lock down) are held at least termly.
- Drills are recorded, including:
 - date of drill

Wigmore Church and Community Under Fives Preschool – Fire Safety

- staff involved and numbers of children
- how long it took to evacuate
- any reason for a delay in achieving the target time and how this will be remedied

Fire precautions

- Fire exit signs are the green ‘running man’ signs and are in place and clearly visible.
- Fire exits by doors are those that show a green light at night.
- Fire doors are not locked during normal working hours.
- Fire evacuation notices are in every room; these are displayed in print large enough to read from a short distance. They say where the assembly point is.
- Fire alarms are in place and tested monthly, and where necessary supplemented with visual warnings. This is recorded.
- Smoke alarms are in place and tested monthly. This is recorded.
- A fire blanket is in place in the kitchen (and any other location where there is a cooker).
- Fire extinguishers are in place and are appropriate

Further guidance

Dynamic Risk Management (Pre-school Learning Alliance 2017)

Fire Safety Record (Early Years Alliance 2019)

Fire Safety Risk Assessment: Educational Premises (HMG 2006): www.gov.uk/government/publications/fire-safety-risk-assessment-educational-premises

Date policy adopted	19 th August 2022
Date of the next review	August 2023
Signed on behalf of the Management Committee	Cathie Barr

02.1a Fire safety risk assessment form template

Risk Area		Carried out by		Date
Fire Hazards: Examples: Ignition; fuel; oxygen	Who is at risk People on premises and those most vulnerable	Level of risk of fire occurring and the risk to people	Control measure Remove and reduce hazards that may cause fire; Remove and reduce risks to people	Review Record, plan, inform, instruct, train and review

Before completing this form, please refer to the five steps in procedure 02.1 Fire safety